



## CITY OF MIAMI

### ADDENDUM NO. 5

September 11, 2009

#### DESIGN-BUILD SERVICES FOR THE DESIGN AND CONSTRUCTION AT GIBSON PARK

RFP NUMBER

08-09-064

**TO: ALL PROSPECTIVE PROPOSERS:**

The following changes, additions, clarifications, and deletions amend the above-captioned Request for Proposals, and shall become an integral part of the Proposal responses and the subsequent Agreement. Please note the contents herein and affix same to the documents you have on hand.

#### **Design Criteria Package**

The following section has been revised as follows:

**10.1 Electrical Engineering Services**, page 87, article 17 states: "The sports field shall be provided with an approved sports lighting system as manufactured and provided by Musco or approved equal by the Architect of record and the City of Miami. The installation shall be approved as their 'Green' type solution with a full 25-year warranty including complete control system with remote monitoring and control capability, and lamp replacement throughout the life of the warranty".

#### **Request for information**

**Q1. Is the synthetic turf specification for the playfield available?**

A1. Yes, it has been posted on the CIP website and is part of this Addendum.


**Q2. Is it a product spec or a performance spec? Are they allowing equivalent/alternates?**

A2. The proposer shall comply with the requirements as stated in the performance specifications.

**Q3. What is the total sq. footage of the area to be turfed?**

A3. Approximately 114,000 sf.

**THIS ADDENDUM IS AN ESSENTIAL PORTION OF THE CONTRACT DOCUMENT  
AND SHALL BE MADE A PART THEREOF.**



\_\_\_\_\_  
Gary Fabrikant  
Assistant Director  
Department of Capital Improvements Program

This addendum should be signed and dated by proposer and submitted as proof of Receipt with the submission of proposals. The proposer by identifying the addendum number in their proposal and by the signing and submission of their proposal shall serve as proof of receipt of this addendum.

NAME OF FIRM: \_\_\_\_\_

SIGNATURE: \_\_\_\_\_

DATE: \_\_\_\_\_