



CITY OF MIAMI

ADDENDUM No. 5

August 26, 2009

INVITATION TO BID No. 08-09-054

Robert King High Park Community Center, B-35868

TO: ALL PROSPECTIVE BIDDERS:

The following changes, additions, clarifications, and/or deletions amend the above-captioned Bid/Contract documents, and shall become an integral part of the bid responses and the subsequent contract. Please note the contents herein and affix same to the documents you have on hand.

All are available as attachments on the CIP website and are part of this Addendum.

1. Extended Bid Due Date:

The bid due date has changed. The ITB submittal date is hereby extended to Wednesday, September 9, 2009 at 2:00 P.M.

2. Change to Project Drawings:

Included in this Addendum are the following documents:

A) Revised Drawings:

a) M-101 – HVAC FLOOR PLAN

3. Additional Requests for Information:

Q1. HVAC - Mechanical drawings do not show the size of duct work, please provide duct sizes.

A1. Please see revised sheet M-101.

Q2. Addendum #3 included reduced drawings. Please provide full size drawings.

A2. Included in Addendum #3, you will find revised drawings in pdf form.

Q3. Sheet numbers A201 (Elevations, A301, A302, A303 (Sections, and A602 (Schedules) call for ¼” tinted glass on Non-Impact Storefront and Operable Windows, to be protected with

accordion shutters, Specifications (Division 8, several pages) call for Impact Resistant Storefront System. Please advise.

A3. Storefront and windows are to be Non-impact and protected with accordion shutters – see revised specification sections 08410, 08420 and 08800.

Q4. Wall Section Page (A302) indicates R5-insulation for exterior block walls, which is ¾” Rigid board. Partition Types Page (A603) indicates-wall type P6 is calling for 1” rigid board. Which one is it?

A4. Provide 1” rigid insulation with a minimum rating of R-5. Furring will be 1” ‘Z’ furring as stated on partition types P-6, P-7, P-9 and P-10.

4. Additional Documentation:

A) Revised Specifications - Sections:

- a. 08410 ALUMINUM SWING ENTRANCES
- b. 08420 ALUMINUM STOREFRONT SYSTEM
- c. 08800 GLASS AND GLAZING

5. Additional Revisions/Deletions

Addendum Number 2, page 6, Additional Revisions/Deletions Section should read as follows:

Written communications may be in the form of e-mail, with a copy to the Office of the City Clerk at marcia@miamigov.com

6. Additional Information:

Bid Form: (Page 3 of 8)

In Part I, please acknowledge any and all addendums in addition to Addendums Nos. 1 - 4 by handwriting the addendum, addendum number and addendum date in the white space to the immediate right of the referenced section.

THIS ADDENDUM IS AN ESSENTIAL PORTION OF THE CONTRACT DOCUMENT AND SHALL BE MADE A PART THEREOF.



Gary Fabrikant, Assistant Director
Department of Capital Improvements Program

This addendum should be signed and dated by Bidder and submitted as proof of receipt with the submission of bids. The Bidder, by identifying the addendum number in their bid proposal and by the signing and submission of their bid, shall serve as proof of receipt of this addendum.

NAME OF FIRM: _____
SIGNATURE: _____
DATE: _____